

To: Crowley Engineering[crowley@eastchicago.com]
Cc: Obed Marrero[OMarrero@eastchicago.com]; Patricia Bodnar[PBodnar@eastchicago.com]; Carla Morgan[cmorgan@eastchicago.com]
From: Alcamo, Thomas
Sent: Mon 9/26/2016 9:27:12 PM
Subject: RE: Zone 3 Site Work Plan Comments

Thanks Gregg. We will get these resolved. We are still on for Friday to begin.

From: Crowley Engineering [mailto:crowley@eastchicago.com]
Sent: Monday, September 26, 2016 4:13 PM
To: Alcamo, Thomas <alcamo.thomas@epa.gov>
Cc: Obed Marrero <OMarrero@eastchicago.com>; Patricia Bodnar <PBodnar@eastchicago.com>; Carla Morgan <cmorgan@eastchicago.com>
Subject: Zone 3 Site Work Plan Comments

Hi Tom:

Per our discussion today, I have the following comments regarding the ER Draft Site Work Plan for Zone 3:

- 1) Please add a bullet point identifying the need to contact East Chicago Utilities (Water, Sewer/Stormwater/ IT) for utility locates in Sections 4.0 and 7.4. Please use the contact information for the departments that has been previously provided to you.
- 2) Please clarify the source of the preexisting drainage issues in Section 8.1. I have asked Obed to follow up on these concerns, especially if they are related to downspouts or gutters. Are issues related to any of the following items in particular?
 - a) Contours/Topography of lot
 - b) High Water Table
 - c) Gutters/Downspouts
 - d) Other causes?
- 3) Please contact East Chicago Water Department (Patti Bodnar - Water Dept. Mgr @ 219-391-8469) to obtain a permit for use of hydrant meter for filling the water truck, and for filling the wet street sweeper, as indicated in Section 8.4. There is a permit fee and deposit requirement, along with a user fee for water consumption.

4) There were no concerns with the SWPPP that has been submitted, per feedback from Obed. However, he intends to inspect the target remediation sites this week, in anticipation of start-up for work activity on Friday, Sep. 30th.

Thanks,

Greg



Gregory D. Crowley, P.E.

Director of Utilities

City of East Chicago

Phone: (219) 391-8466